

# USING INNOVATIVE TECHNOLOGIES TO CREATE A BARRIER-FREE AIRPORT

# Agenda


- Project introduction
- Timeline
- Design approach/phasing and construction
- ROC vision
- System integration
- Results

# PROJECT INTRODUCTION

- June 2016 Upstate Airport Economic Development and Revitalization is announced by Governor Andrew Cuomo
- ROC wins the \$39.8 M in NYSDOT Grant
- ROC sets \$79 M budget for the Renovation Project
- ROC/Consultants sets goals for the project

# TIMELINE

- Design/Bid and Award 24 projects 10 months



- Strategic phasing
- Releasing early packages to extend construction time line
- VE


# PROJECT INTEGRATION

- Project integration County/Airport/Designer/CM




# DESIGN APPROACH/PHASING AND CONSTRUCTION


General Overview




Existing Checkpoint and Deplaning Route




Enhanced Checkpoint & Exit Lane



Food court & Concession Enhancement



Concourse Technology & Amenities



# ROC VISION

The goal of the Program was to build a more efficient and state-of-the-art facility responding to the necessities of the community.



- Barrier-free airport
- Security and satisfaction of passengers
- Broadening the opportunities for business

# ROC VISION

Why a free-barrier airport?

- Rochester is home to the NTID (National Technical Institute for the Deaf) largest technological institute in the world for the deaf.
- Innovation – to be different – on the edge of technology



# BARRIER-FREE AIRPORT



# ROC VISION

Pairing security and satisfaction of passengers

- One point of entry and exit





# ROC VISION

- Broadening the opportunities for business



# ROC VISION

Broadening the opportunities for business






# ROC VISION

Broadening the opportunities for business



# SYSTEM INTEGRATION


## Taking advantage of FIDS




# SYSTEM INTEGRATION

## Holdroom Lighting Retrofit

- Performance spec
- ETL approval
- In situ installation



# SYSTEM INTEGRATION







# SYSTEM INTEGRATION


## Holdroom gate signs



# SYSTEM INTEGRATION




# SYSTEM INTEGRATION





# SYSTEM INTEGRATION



# SYSTEM INTEGRATION

## Energy savings

Chiller Replacement					
Base	Chiller Nominal Load (Tons)	Chiller kW/Ton	Hours / Season	Annual kWh	Annual \$@\$.08 / kWh
	525	0.88	4320	1995840	\$ 159,667.20
Current	Chiller Nominal Load (Tons)	Chiller kW/Ton	Hours / Season	Annual kWh	Annual \$@\$.08 / kWh
	525	0.45	4320	1020600	\$ 81,648.00
Net				975240	\$ 78,019.20

Concourse Overhang Heating									
Base	Boiler Efficiency	Surface Area (Outdoor Exposure)	U	Cavity Temperature	μ OA Temp	μΔT (Cavity v OA)	Hours / Season	Annual Loss (mmbtu)	Annual \$@\$.00/mCF
	0.77	23,761	0.0833	90	36	54	6000	832.84465	\$ 3,331.38
Current	Boiler Efficiency	Surface Area (Outdoor Exposure)	U	Cavity Temperature	μ OA Temp	μΔT (Cavity v OA)	Hours / Season	Annual Loss (mmbtu)	Annual \$@\$.00/mCF
	0.77	23,761	0.0833	55	36	19	4320	210.98731	\$ 843.95
Net								621.85734	\$ 2,487.43

DCV Integration With FIDS																			
Boiler Eff	Chiller kw /ton	\$/mcf	Cost per kWh																
0.78	0.45	\$ 4.00	\$ 0.08																
Base	μ Heating Season OA Temp	μ Cooling Season OA Temp	Hold Room Min Vent Rate (cfm)	Hold Room 80% Vent Rate (cfm)	μ Cooling Supply Air Temp	μ Reheat Supply Air Temp	Hrs / Heating Season	Hrs / Cooling Season	Hrs / Heating Season @min Vent Rate	Hrs / Cooling Season @min Vent Rate	Heating Load @ 80% Vent Rate (mmbtu/h)	Cooling Load @ 80% Vent Rate (mmbtu)	Heating Load @ min Vent Rate (mmbtu)	Cooling Load @ min Vent Rate (mmbtu)	Heating mmbtu/yr	Cooling mmbtu/yr	Heating \$/yr	Cooling \$/yr	Total Hold Room\$/yr
	36	78	9000	22000	55	82	3100	3700	620	740	0.64152	0.54648	0.26244	0.22356	1,753.68	1783.0152	\$8,993.24	\$11,886.77	\$ 20,880.01
Current	μ Heating Season OA Temp	μ Cooling Season OA Temp	Hold Room Min Vent Rate (cfm)	Hold Room 80% Vent Rate (cfm)	μ Cooling Supply Air Temp	μ Reheat Supply Air Temp	Hrs / Heating Season	Hrs / Cooling Season	Hrs / Heating Season @min Vent Rate	Hrs / Cooling Season @min Vent Rate	Heating Load @ 80% Vent Rate (mmbtu/h)	Cooling Load @ 80% Vent Rate (mmbtu)	Heating Load @ min Vent Rate (mmbtu)	Cooling Load @ min Vent Rate (mmbtu)	Heating mmbtu/yr	Cooling mmbtu/yr	Heating \$/yr	Cooling \$/yr	Total Hold Room\$/yr
	36	78	9000	22000	55	82	3100	3700	2325	2220	0.64152	0.54648	0.26244	0.22356	1,107.35	1305.0936	\$5,678.72	\$ 8,700.62	\$ 14,379.35
Net															646.33	477.92	3,314.52	3,186.14	\$ -

Gate Hold Room Lighting					
Base	# Fixtures	Watts per Fixture	Run hours per year	kWh/yr	\$/yr @ \$.08/kWh
	768	49	6000	225,792.00	\$ 18,063.36
Current	# Fixtures	Watts per Fixture	Run hours per year	kWh/yr	\$/yr @ \$.08/kWh
	768	13	6000	59904	\$ 4,792.32
Net				165,888.00	\$ 13,271.04

Totals	
Chiller Replacement	\$ 78,019.20
Overhang Heating	\$ 2,487.43
DCV / FIDS Integration	\$ 6,500.66
Hold Room Lighting (LED)	\$ 13,271.04
Total	\$ 100,278.33



# **USING INNOVATIVE TECHNOLOGIES TO CREATE A BARRIER-FREE AIRPORT**